



Company: Small Data Garden
 Product name: IOTSU® rH Temp for LoRaWAN®
 Product code: IOTSU®L3 TH02
 Rev: 1.8_21stDec 2023



IOTSU® rH Temp for LoRaWAN®

IOTSU® rH Temp is a wireless indoor device that measures air temperature and relative humidity. IOTSU® rH Temp can be used for long-time monitoring of real estates and building structures.

The device can be mounted using screws or adhesive tape. Installation of this maintenance-free device is quick and easy. Transmission and measurement cycles can be adjusted according to the need using downlinks.

IOTSU® rH Temp uses the global LoRaWAN® network connection. There is no need for external power supply. Depending on transmission settings and environmental factors the battery of the device can last 5 years.

MEASURING AND RECORDING:	
	<ul style="list-style-type: none"> Temperature Humidity
TECHNICAL SPECIFICATIONS:	
Dimensions	: 63 x 114 x 30 mm
Weight	: 111 g with battery
Sensors	: temperature, humidity
Transmission cycle	: 2 h, configurable via downlink
Measurement cycle	: Transmission cycle /4
Connectivity	: LoRaWAN® 1.0.4
Battery	: Size C, 3.6 V, replaceable
Expected battery life	: 5 years with default setting, Transmissions at SF12/DR0
Operating Conditions	: 0 °C...+50 °C, Relative humidity 10...95 % (Non-condensing)
Typical Accuracy	: Temperature: ±0.2 °C Humidity: ±2 %
Certifications	: CE
Mounting	: Screws, adhesive tape

Small Data Garden Oy's (SDG) products (IOTSU® Products) shall be used according to the manual and other instructions and not be used in any other way than their intended use defined by SDG. IOTSU® Products are designed for LPWAN technologies collecting non-critical information. SDG will not be held liable for any damage which may result from inaccurate readings and delayed data transmission. In case regular calibration of IOTSU® Products is needed, SDG shall not be responsible for this, and it is the Customer's responsibility to obtain calibration from a suitable service provider. For more information see SDG's General Terms and conditions for the supply of products and Legal Notices.



Measurement ranges

Range and resolution of the measurements depends on sensor type and the data transfer structure. To ensure the long battery life of IOTSU®, data packets sent over wireless networks are optimized.


Temperature

Sensor model: Sensirion SHTC3

Resolution: 0.1 °C

Range: 0...+50 °C

Sensor accuracy: typical ± 0.2 °C



Sensor's accuracy. Source: Sensirion SHTC3 datasheet Version 3


Relative humidity

Sensor model: Sensirion SHTC3

Resolution: 1 % RH

Range: 0...100 % RH, non-condensing

Sensor accuracy: typical ± 2.0 % RH



Sensor's accuracy. Source: Sensirion SHTC3 datasheet Version 3

Small Data Garden Oy's (SDG) products (IOTSU® Products) shall be used according to the manual and other instructions and not be used in any other way than their intended use defined by SDG. IOTSU® Products are designed for LPWAN technologies collecting non-critical information. SDG will not be held liable for any damage which may result from inaccurate readings and delayed data transmission. In case regular calibration of IOTSU® Products is needed, SDG shall not be responsible for this, and it is the Customer's responsibility to obtain calibration from a suitable service provider. For more information see SDG's General Terms and conditions for the supply of products and Legal Notices.



CALIBRATION

The IOTSU® device has been configured to periodically perform automatic reference calibration to any onboard sensors that require it. The following describes the calibration methods for each sensor:

Temperature and humidity sensor

Factory calibrated. Temperature long-term drift <0.02 °C/year. Relative humidity long-term drift <0.25 % rH/year.

Small Data Garden Oy's (SDG) products (IOTSU® Products) shall be used according to the manual and other instructions and not be used in any other way than their intended use defined by SDG. IOTSU® Products are designed for LPWAN technologies collecting non-critical information. SDG will not be held liable for any damage which may result from inaccurate readings and delayed data transmission. In case regular calibration of IOTSU® Products is needed, SDG shall not be responsible for this, and it is the Customer's responsibility to obtain calibration from a suitable service provider. For more information see SDG's General Terms and conditions for the supply of products and Legal Notices.



Legal Notices

Small Data Garden Oy's (SDG) products (IOTSU® Products) shall be used according to the manual and other instructions and not be used in any other way than their intended use defined by SDG.

The user right of the firmware of SDG is limited to the version and specifications confirmed by SDG. Any unauthorised usage of device is prohibited and must be suspended by request of SDG. In addition, SDG is entitled to charge for unauthorised usage including administrative and solving cost. SDG shall not be responsible for damages caused by the user connecting the SDG's products (IOTSU® Products) and/or using the IOTSU® Products in any other way than their intended use nor for any damages caused by materials or product design defined by the client or by the working or manufacturing processes the client has determined.

IOTSU® Products are designed for collecting non-critical information for optimising energy consumption in long term usage and the IOTSU® Products are not intended to be used for life and security critical solutions. We rely on high-quality sensor, component and software suppliers and manufacturers and IT, LP-WAN and cloud service providers. However, for the reason that the accuracy and redundancy is depended among other things on operating circumstances, radiotechnology specifications and coverage, and because SDG relies on specifications provided by its suppliers, SDG will not be held liable for any damage which may result from inaccurate readings.

All information, including product design and specifications, in this document is subject to change without notice. SDG reserves all rights to revise or update information in this document without prior notice. SDG assumes no responsibility for any errors that may appear in this document.

In case regular calibration of IOTSU® Products is needed, SDG shall not be responsible for this, and it is the customer's responsibility to obtain calibration from a suitable service provider. For more information see SDG's General Terms and conditions for the supply of products and Legal Notices.

For more information see SDG's General Terms and conditions for the supply of products.

